



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.06	25.4			Y
2	8.07	25			Y
3	8.05	23.9			Y
4	8.11	24.4			Y
5	8.06	25.5			Y
6	8.03	25.6			Y
7	8.00	22.3			Y
8	7.99	23.4			Y
9	7.98	25.4			Y
10	7.96	22.4			Y
11	7.96	23.7			Y
12	7.99	22.9			Y
13	7.97	23.1			Y
14	7.97	21.3			Y
15	7.97	24			Y
16	7.99	20.2			Y
17	8.02	20.7			Y
18	8.06	19.3			Y
19	8.07	28.7			Y
20	8.08	27			Y
21	8.04	24			Y
22	8.04	23.6			Y
23	8.06	24			Y
24	8.04	25.8			Y
25	8.02	24.2			Y
26	8.06	24.9			Y
27	7.99	24.8			Y
28	7.98	23.2			Y
29	7.95	25.3			Y
30	7.97	22.7			Y
31	8.08	23.9			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: July 2024

Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH

Alk  (Alkalinity)

PO<sub>4</sub>  (Orthophosphate)

Sili  (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 8/2/2024 541-704-2301