



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH   | Alk  | Phos | Sili | Y/N |
|-----|------|------|------|------|-----|
| 1   | 8.09 | 23.1 |      |      | Y   |
| 2   | 8.10 | 26.5 |      |      | Y   |
| 3   | 8.12 | 24.4 |      |      | Y   |
| 4   | 8.10 | 23.3 |      |      | Y   |
| 5   | 8.06 | 22.9 |      |      | Y   |
| 6   | 8.03 | 20.5 |      |      | Y   |
| 7   | 8.02 | 21.2 |      |      | Y   |
| 8   | 8.03 | 21.7 |      |      | Y   |
| 9   | 8.02 | 23.3 |      |      | Y   |
| 10  | 8.01 | 20.6 |      |      | Y   |
| 11  | 8.00 | 22.4 |      |      | Y   |
| 12  | 8.05 | 22.8 |      |      | Y   |
| 13  | 8.04 | 22.3 |      |      | Y   |
| 14  | 8.01 | 23   |      |      | Y   |
| 15  | 8.01 | 21.2 |      |      | Y   |
| 16  | 8.05 | 21   |      |      | Y   |
| 17  | 8.08 | 23.6 |      |      | Y   |
| 18  | 8.06 | 23.2 |      |      | Y   |
| 19  | 8.05 | 23.6 |      |      | Y   |
| 20  | 8.07 | 21.6 |      |      | Y   |
| 21  | 8.09 | 24.2 |      |      | Y   |
| 22  | 8.08 | 21   |      |      | Y   |
| 23  | 8.06 | 23.3 |      |      | Y   |
| 24  | 8.03 | 21.4 |      |      | Y   |
| 25  | 8.06 | 24.2 |      |      | Y   |
| 26  | 8.05 | 22.7 |      |      | Y   |
| 27  | 8.07 | 25.5 |      |      | Y   |
| 28  | 7.99 | 25   |      |      | Y   |
| 29  | 8.01 | 24.2 |      |      | Y   |
| 30  | 8.05 | 22.5 |      |      | Y   |

<<Have minimums been met for this day?

**ENTRY POINT**

**PWS ID: 4100012 B**

**System Name:** Albany

**Entry Point:** AM Drinking Water Plant

**Sample Period:** September 2024

Month/Year

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by State:**

pH 7.8

Alk 18.0 (Alkalinity)

PO4  (Orthophosphate)

Sili  (Silicate)

**Print Name:** Chris Germond

**Signature:** Chris Germond

**Date & Phone#:** 10/3/24 591-704-2309