



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.06	25			Y
2	8.12	22.5			Y
3	8.13	24			Y
4	8.09	19.8			Y
5	8.06	21.3			Y
6	8.04	24.1			Y
7	8.00	24			Y
8	8.01	23.1			Y
9	8.05	22.2			Y
10	8.08	22.2			Y
11	8.09	25.2			Y
12	8.12	22.3			Y
13	8.15	22.2			Y
14	8.13	22.5			Y
15	8.10	23.2			Y
16	8.07	20.1			Y
17	8.06	23.3			Y
18	8.09	22.9			Y
19	8.06	20.7			Y
20	8.05	21.7			Y
21	8.05	23.5			Y
22	8.05	22.5			Y
23	8.06	22.3			Y
24	8.06	24.8			Y
25	8.06	23.3			Y
26	8.08	22.8			Y
27	8.07	24.6			Y
28	8.02	24.3			Y
29	8.01	22.8			Y
30	7.95	24.9			Y
31	7.94	23.6			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: October 2024

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 11/8/2024 541-704-2309

Send to DHS within 10 days after end of sample period