



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.97	26.1			Y
2	7.97	22.3			Y
3	7.96	22.3			Y
4	7.95	25.6			Y
5	7.99	22.6			Y
6	8.01	22.1			Y
7	8.00	21.7			Y
8	8.01	24.1			Y
9	8.00	24.6			Y
10	7.95	24.2			Y
11	7.92	26			Y
12	8.03	25.2			Y
13	8.00	24			Y
14	8.06	21.6			Y
15	7.96	20.3			Y
16	7.91	23.5			Y
17	7.90	22.7			Y
18	7.98	22			Y
19	7.94	18.6			Y
20	7.93	18.7			Y
21	8.00	20.8			Y
22	8.01	19.9			Y
23	8.04	20.9			Y
24	8.02	21.2			Y
25	8.01	19.8			Y
26	8.01	21.8			Y
27	8.03	21.8			Y
28	8.01	22.4			Y
29	8.03	21.6			Y
30	8.05	21.4			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: November 2024

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 541-704-2309 12/9/24

Send to DHS within 10 days after end of sample period