



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.06	23			Y
2	8.08	25.2			Y
3	8.05	24.4			Y
4	8.03	24.4			Y
5	8.04	21.6			Y
6	8.04	24.9			Y
7	8.01	25.5			Y
8	8.03	25.9			Y
9	8.05	23.7			Y
10	8.05	23.1			Y
11	8.06	21.7			Y
12	8.04	24.5			Y
13	8.06	21.8			Y
14	8.04	21.7			Y
15	8.09	22.2			Y
16	8.05	22			Y
17	8.06	20.8			Y
18	8.05	21.9			Y
19	8.04	21.5			Y
20	8.01	23.6			Y
21	8.02	22.2			Y
22	8.01	22.8			Y
23	7.99	23.2			Y
24	8.07	23.7			Y
25	8.07	21.4			Y
26	8.03	22.8			Y
27	8.01	19.7			Y
28	8.01	21			Y
29	7.98	19.5			Y
30	8.01	19.6			Y
31	7.96	19.9			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: December 2024

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 1-3-25 541-709-2309