



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.96	20.1			Y
2	7.97	21.6			Y
3	8.03	21.7			Y
4	8.10	22.7			Y
5	8.06	22			Y
6	7.97	23.4			Y
7	7.95	21.1			Y
8	7.91	20.8			Y
9	7.92	20.6			Y
10	7.96	22.1			Y
11	8.05	19.7			Y
12	7.95	22.5			Y
13	7.95	23.3			Y
14	7.98	21.6			Y
15	7.97	26.3			Y
16	7.96	21.2			Y
17	7.98	20.8			Y
18	8.01	20.9			Y
19	7.98	21.2			Y
20	8.03	21.5			Y
21	8.06	26.3			Y
22	8.06	23.1			Y
23	8.01	23.4			Y
24	7.97	22.9			Y
25	7.99	22.9			Y
26	8.01	22			Y
27	7.99	27.9			Y
28	7.98	23.5			Y
29	8.04	24			Y
30	8.11	23.9			Y
31	8.02	23			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: January 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 2/5/2025 541-204-2309

Send to DHS within 10 days after end of sample period