



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.99	23			Y
2	8.02	23.3			Y
3	8.03	22.5			Y
4	8.06	22.4			Y
5	8.09	22.3			Y
6	8.06	23.6			Y
7	8.00	21.7			Y
8	8.00	22.9			Y
9	7.99	23.4			Y
10	8.00	26			Y
11	8.02	22.9			Y
12	8.03	23.6			Y
13	7.98	22.8			Y
14	7.97	22.7			Y
15	8.01	22.9			Y
16	7.92	22.8			Y
17	7.95	24.5			Y
18	7.98	26			Y
19	7.96	19.3			Y
20	7.92	22.4			Y
21	7.95	20.3			Y
22	7.98	20.1			Y
23	7.90	20.7			Y
24	7.90	23.1			Y
25	7.92	18.2			Y
26	7.94	18.6			Y
27	7.95	18.2			Y
28	7.92	21.1			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: February 2025

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 3/4/2025 541-704-2309