

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.92	19.3			Y
2	7.92	21.5			Y
3	8.06	20.9			Y
4	8.07	21			Y
5	8.14	22.4			Y
6	8.16	21.2			Y
7	8.14	20.9			Y
8	8.12	20.5			Y
9	8.13	21.7			Y
10	8.16	20.6			Y
11	8.11	23.6			Y
12	8.03	20.1			Y
13	8.02	20.6			Y
14	7.99	20.8			Y
15	8.04	21.3			Y
16	8.01	21.9			Y
17	7.94	19.3			Y
18	7.96	20.1			Y
19	7.95	20.4			Y
20	8.02	22			Y
21	8.07	20.4			Y
22	8.08	18.5			Y
23	8.06	22.1			Y
24	8.06	22.2			Y
25	8.03	19.9			Y
26	8.03	19.5			Y
27	8.05	18.1			Y
28	8.03	18.7			Y
29	8.03	18.4			Y
30	8.05	18.3			Y
31	8.05	Plant Offline			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: March 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 4/8/25 541-704-2309

Send to DHS within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405