

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.04	Plant off			Y
2	8.08				Y
3	8.12				Y
4	8.06	18.5			Y
5	7.92	20			Y
6	7.98	24.5			Y
7	7.86	21.5			Y
8	7.96	21.7			Y
9	8.04	18.9			Y
10	8.05	24.9			Y
11	8.09	22			Y
12	8.11	20.3			Y
13	8.08	21.5			Y
14	8.08	24.9			Y
15	8.03	23.1			Y
16	8.10	20.9			Y
17	8.10	20			Y
18	8.06	19.8			Y
19	8.08	20.6			Y
20	8.06	20.2			Y
21	8.09	Plant off			Y
22	8.12				Y
23	8.12				Y
24	8.15	19.8			Y
25	8.10	19.9			Y
26	7.98	21.3			Y
27	7.98	21.7			Y
28	7.98	21.4			Y
29	7.96	21.5			Y
30	8.02	19.6			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: April 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 541-704-2309 5/8/25

Send to DHS within 10 days after end of sample period