



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.03	20.1			Y
2	8.06	18.7			Y
3	8.03	20.9			Y
4	8.07	21.8			Y
5	8.05	24.2			Y
6	8.09	23.1			Y
7	8.19	20.8			Y
8	8.21	21.1			Y
9	8.25	23.3			Y
10	8.33	21.4			Y
11	8.25	23.7			Y
12	8.18	21.9			Y
13	8.18	21.6			Y
14	8.17	24.5			Y
15	8.19	20.8			Y
16	8.20	20.4			Y
17	8.18	20.3			Y
18	8.13	24.5			Y
19	8.15	26.1			Y
20	8.18	23.6			Y
21	8.19	21.2			Y
22	8.15	20.3			Y
23	8.18	21.3			Y
24	8.19	21.8			Y
25	8.22	21			Y
26	8.17	27.8			Y
27	8.17	21.9			Y
28	8.12	20.6			Y
29	8.17	26.3			Y
30	8.14	20.2			Y
31	8.12	20.3			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: May 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 6/6/2025 541-704-2309

Send to DHS within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405