

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.10	21.6			Y
2	8.15	23.1			Y
3	8.17	23.2			Y
4	8.12	21			Y
5	8.01	21.1			Y
6	8.00	23			Y
7	7.97	21.9			Y
8	7.96	23.3			Y
9	7.93	24.5			Y
10	7.99	21.5			Y
11	8.01	22.9			Y
12	8.05	20.9			Y
13	8.07	20.4			Y
14	8.09	25.3			Y
15	8.07	21			Y
16	8.06	21.3			Y
17	8.06	20.1			Y
18	8.04	21.5			Y
19	8.07	20.9			Y
20	8.08	20.3			Y
21	8.09	21.6			Y
22	8.16	23			Y
23	8.10	23.9			Y
24	8.06	20.5			Y
25	8.05	20.5			Y
26	8.09	21			Y
27	8.07	23			Y
28	8.07	20.8			Y
29	8.05	27.2			Y
30	8.03	23.3			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: June 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 7-7-2025 541-704-2309

Send to DHS within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405