

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.07	23.9			Y
2	8.15	21.9			Y
3	8.23	23			Y
4	8.23	22.4			Y
5	8.24	22.8			Y
6	8.21	23.9			Y
7	8.20	22.5			Y
8	8.11	24.2			Y
9	8.11	21.2			Y
10	8.20	21.7			Y
11	8.28	22.5			Y
12	8.06	22.8			Y
13	8.05	24.9			Y
14	8.09	21.2			Y
15	8.12	23			Y
16	8.16	22			Y
17	8.10	21.5			Y
18	8.18	22.2			Y
19	8.06	21.8			Y
20	7.99	23.1			Y
21	7.99	20.3			Y
22	8.01	24.2			Y
23	7.97	23.1			Y
24	7.96	22.5			Y
25	8.01	22.1			Y
26	8.00	22.3			Y
27	8.00	23.9			Y
28	8.03	21.3			Y
29	8.01	22.4			Y
30	7.99	21.8			Y
31	8.02	21.7			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: July 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 8/6/25 541-704-2309

Send to DHS within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405