

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.01	20.4			Y
2	8.02	22.4			Y
3	8.00	23.6			Y
4	8.04	22.4			Y
5	8.09	24.3			Y
6	8.02	24.1			Y
7	8.09	21.6			Y
8	8.40	21.4			Y
9	8.36	21.9			Y
10	8.34	21.9			Y
11	8.19	22.8			Y
12	8.16	22.2			Y
13	8.19	24.4			Y
14	8.36	21.9			Y
15	8.34	20.3			Y
16	8.32	21.9			Y
17	8.26	23.8			Y
18	8.33	21.5			Y
19	8.26	22			Y
20	8.22	21.7			Y
21	8.20	21.5			Y
22	8.18	23.2			Y
23	8.20	24.9			Y
24	8.24	21.7			Y
25	8.12	24			Y
26	8.10	23			Y
27	8.05	23.4			Y
28	8.02	21.4			Y
29	8.07	21.2			Y
30	8.12	22			Y
31	8.10	22.4			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: August 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 541-704-2309

Send to DHS within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405