

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.08	22.8			Y
2	8.09	21.1			Y
3	8.09	22			Y
4	8.08	19.8			Y
5	8.10	21			Y
6	8.12	19.9			Y
7	8.13	20.8			Y
8	8.13	19.7			Y
9	8.14	25			Y
10	8.12	22.4			Y
11	8.12	22.2			Y
12	8.11	22.6			Y
13	8.08	21.6			Y
14	8.05	21.7			Y
15	8.04	23.5			Y
16	8.02	23.2			Y
17	8.03	21.5			Y
18	8.04	22.5			Y
19	8.06	23.7			Y
20	8.05	24			Y
21	8.04	23			Y
22	8.05	22.6			Y
23	8.04	22			Y
24	8.06	23.7			Y
25	8.07	22.2			Y
26	8.13	23.4			Y
27	8.02	23.5			Y
28	8.03	25.5			Y
29	8.02	20.6			Y
30	7.95	21.7			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: September 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 10/3/25 541-704-2309

Send to DHS within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405