

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.98	21.7			Y
2	7.94	21.5			Y
3	7.99	21.4			Y
4	7.95	22.1			Y
5	7.95	25.2			Y
6	7.94	22.8			Y
7	7.96	21.9			Y
8	7.91	22.5			Y
9	7.95	23			Y
10	7.98	22.7			Y
11	7.97	22			Y
12	7.98	21.9			Y
13	7.98	21.9			Y
14	7.97	22.1			Y
15	7.98	23.8			Y
16	7.99	23.4			Y
17	8.03	23.2			Y
18	8.01	23.5			Y
19	8.01	22			Y
20	7.97	23.1			Y
21	7.88	23.2			Y
22	7.96				Y
23	8.24	25.2			Y
24	8.12	24			Y
25	8.02	25			Y
26	8.02	23.8			Y
27	8.03	22.9			Y
28	8.02	22.5			Y
29	8.03	24.5			Y
30	8.03	24.7			Y
31	8.03	21.1			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: October 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 11/6/2025 541-704-2309

Send to DHS within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405