

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.03	23			Y
2	8.01	23.9			Y
3	7.98	21.8			Y
4	7.96	21.6			Y
5	7.96	24.1			Y
6	7.97	24.2			Y
7	7.93	23.8			Y
8	7.98	22			Y
9	7.98	21.5			Y
10	7.98	21.9			Y
11	7.96	22.3			Y
12	7.96	25.8			Y
13	8.01	24.1			Y
14	8.09	23.6			Y
15	8.16	23.8			Y
16	8.12	24			Y
17	8.09	25.2			Y
18	8.12	24.3			Y
19	8.13	24.5			Y
20	8.11	26.2			Y
21	8.05	26.2			Y
22	8.09	24.6			Y
23	8.08	24.7			Y
24	8.10	27.1			Y
25	8.11	25.1			Y
26	8.11	24.9			Y
27	8.11	25.8			Y
28	8.12	26			Y
29	8.12	25.2			Y
30	8.16	25.8			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: November 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 12/8/25 541-704-2309

Send to DHS within 10 days after end of sample period