

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.15	25.2			Y
2	8.14	24.6			Y
3	8.12	24.6			Y
4	8.07	25.1			Y
5	8.08	25.8			Y
6	8.06	26.1			Y
7	8.01	20.7			Y
8	8.05	21.8			Y
9	8.02	20.2			Y
10	7.85	20.5			Y
11	7.83	19.6			Y
12	8.02	19.4			Y
13	8.10	20.2			Y
14	8.08	20.2			Y
15	8.08	20.7			Y
16	8.10	21			Y
17	8.08	21.1			Y
18	8.13	22			Y
19	7.98	22.2			Y
20	7.89	18.1			Y
21	7.98	20.9			Y
22	8.04	21.2			Y
23	8.09	18.9			Y
24	8.11	22.4			Y
25	8.09	22			Y
26	8.07	22.5			Y
27	8.07	22.2			Y
28	8.11	20.1			Y
29	8.13	20.4			Y
30	8.16	20.1			Y
31	8.17	22.3			Y

<<Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: December 2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO₄ (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 1/7/26

541-704-2309

Send to DHS within 10 days after end of sample period

OHA-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405