



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	8.15	21.9			Y
2	8.16	22.5			Y
3	8.15	22			Y
4	8.12	20.3			Y
5	8.11	21.1			Y
6	8.15	22.4			Y
7	8.16	19.9			Y
8	8.16	21.3			Y
9	8.13	22.6			Y
10	8.14	21.9			Y
11	8.15	21			Y
12	8.15	20.2			Y
13	8.12	21.4			Y
14	8.06	21.5			Y
15	8.07	22.8			Y
16	8.06	25.5			Y
17	8.07	24.2			Y
18	8.08	22.1			Y
19	8.08	22.1			Y
20	8.07	22			Y
21	8.07	21.3			Y
22	8.06	25.4			Y
23	8.04	21.1			Y
24	8.07	26.2			Y
25	8.05	22.6			Y
26	8.06	24.3			Y
27	8.06	21.7			Y
28	8.06	24.6			Y
29	8.07	25.1			Y
30	8.08	25			Y
31	8.07	24.9			Y

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: January 2026

Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality**

Parameters as set by State:

pH 7.8

Alk 18.0 (Alkalinity)

PO4   (Orthophosphate)

Sili   (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 2/7/26 541-704-2309