



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.07	20.5			Y
2	8.10	20.8			Y
3	8.07	23.7			Y
4	8.05	24.5			Y
5	8.03	23.6			Y
6	8.05	25.4			Y
7	8.06	25.7			Y
8	8.08	20.9			Y
9	8.05	20.3			Y
10	8.00	20.1			Y
11	8.05	21.9			Y
12	8.04	24.1			Y
13	8.02	23.3			Y
14	8.04	23.5			Y
15	8.06	20			Y
16	8.04	23.3			Y
17	8.01				Y
18	8.01	18			Y
19	8.03	20.1			Y
20	8.02	18.7			Y
21	7.99	21.7			Y
22	7.92	25.2			Y
23	8.00	23.5			Y
24	7.89	24.9			Y
25	7.87	21.5			Y
26	7.95	21.3			Y
27	8.06	21.3			Y
28	8.10	22.1			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 4100012 B

System Name: Albany

Entry Point: AM Drinking Water Plant

Sample Period: February 2026

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality

Parameters as set by State:

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name: Chris Germond

Signature: Chris Germond

Date & Phone#: 541-924-404-2309