

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.7				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.7				Y
7	7.8				Y
8	7.8				Y
9	8.0				Y
10	8.0				Y
11	8.0				Y
12	7.8				Y
13	7.9				Y
14	7.9				Y
15	7.8				Y
16	7.7				Y
17	7.7				Y
18	7.6				Y
19	7.8				Y
20	7.8				Y
21	7.8				Y
22	7.9				Y
23	7.9				Y
24	7.7				Y
25	7.7				Y
26	7.9				Y
27	8.0				Y
28	8.1				Y
29	8.0				Y
30	8.0				Y
31	7.8				Y

(No = N = Excursion) Total N's **10**

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 **00018**

System Name: Scaravel Hill Water

Entry Point: Yih Tank/pump station

Sample Period: 1-21
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Montie TORGESSON
Signature: [Signature]
Date: 2-12-24

Send to DWP within 10 days after end of sampling period