

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.9				Y
3	7.9				Y
4	7.7				Y
5	7.8				Y
6	7.9				Y
7	8.0				Y
8	8.0				Y
9	7.8				Y
10	7.8				Y
11	7.7				Y
12	7.9				Y
13	7.9				Y
14	7.9				Y
15	8.0				Y
16	8.1				Y
17	8.0				Y
18	7.8				Y
19	7.8				Y
20	7.8				Y
21	7.7				Y
22	7.7				Y
23	7.9				Y
24	7.9				Y
25	7.8				Y
26	7.8				Y
27	7.7				Y
28	7.8				Y
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 **00018**

System Name: Scravel Hill Water

Entry Point: Yih Tank/pump station

Sample Period: Feb 2021
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Montie TORGESON

Signature: [Signature]

Date: 2-1-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's **0**