

Day	pH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.8				Y
3	7.7				Y
4	7.8				Y
5	7.8				Y
6	7.9				Y
7	7.9				Y
8	7.9				Y
9	7.7				Y
10	7.7				Y
11	7.7				Y
12	7.8				Y
13	7.7				Y
14	7.6				Y
15	7.8				Y
16	7.8				Y
17	7.7				Y
18	7.9				Y
19	7.9				Y
20	7.7				Y
21	7.7				Y
22	7.7				Y
23	7.6				Y
24	7.7				Y
25	7.8				Y
26	7.6				Y
27	7.9				Y
28	7.9				Y
29	7.8				Y
30	7.8				Y
31					

<<Have minimums been met for this day?

## ENTRY POINT

PWS ID: 41 00018

System Name: Scrave Hill Water

Entry Point: Yih Tank/pump station

Sample Period: 4-21  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH 7.2  
 Alk   (Alkalinity)  
 PO4   (Orthophosphate)  
 Other   ( )

Print Name: Montie TORGESSON

Signature: *Montie Torgesson*

Date: 5-3-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0