

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	7.7				Y
4	7.7				Y
5	7.5				Y
6	7.6				Y
7	7.5				Y
8	7.5				Y
9	7.5				Y
10	7.7				Y
11	7.8				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.8				Y
17	7.8				Y
18	7.7				Y
19	7.8				Y
20	7.9				Y
21	7.7				Y
22	7.6				Y
23	7.6				Y
24	7.8				Y
25	7.8				Y
26	7.9				Y
27	7.7				Y
28	7.7				Y
29	7.8				Y
30	7.6				Y
31	7.6				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

## ENTRY POINT

PWS ID: 41 00018

System Name: Scrabell Hill Water  
 Entry Point: Yih Tank/pump station  
 Sample Period: 5-2015  
 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

pH	<span style="border: 1px solid black; padding: 2px;">7.2</span>	
Alk	<span style="border: 1px solid black; padding: 2px;"></span>	(Alkalinity)
PO4	<span style="border: 1px solid black; padding: 2px;"></span>	(Orthophosphate)
Other	<span style="border: 1px solid black; padding: 2px;"></span>	(_____)

Print Name: Montie TORGESSON  
 Signature: *Montie Torgesson*  
 Date: 6-1-2015

Send to DWP within 10 days after end of sampling period