

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.7				Y
3	7.9				Y
4	7.9				Y
5	7.9				Y
6	7.9				Y
7	7.8				Y
8	7.9				Y
9	8.0				Y
10	8.0				Y
11	7.8				Y
12	7.8				Y
13	7.7				Y
14	7.8				Y
15	7.8				Y
16	7.9				Y
17	7.9				Y
18	7.8				Y
19	7.7				Y
20	7.9				Y
21	7.9				Y
22	7.7				Y
23	7.6				Y
24	7.6				Y
25	7.6				Y
26	7.8				Y
27	7.8				Y
28	7.9				Y
29	7.9				Y
30	7.8				Y
31	7.8				Y

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Scrabell Hill Water

Entry Point: Yih Tank/pump station

Sample Period: July 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	()

Print Name: Montie TORGESSON

Signature: *Montie Torgesson*

Date: 8-1-2021

Send to DWP within 10 days after end of sampling period