

Day	pH	Alk	Phos	Other	Y/N
1	7.8				y
2	7.8				y
3	7.9				y
4	7.9				y
5	7.8				y
6	7.7				y
7	7.7				y
8	7.7				y
9	7.9				y
10	8.0				y
11	8.0				y
12	7.8				y
13	7.8				y
14	7.7				y
15	7.9				y
16	7.9				y
17	7.7				y
18	7.8				y
19	7.7				y
20	7.9				y
21	8.0				y
22	8.0				y
23	8.0				y
24	8.0				y
25	7.8				y
26	7.9				y
27	7.9				y
28	8.0				y
29	8.0				y
30	7.9				y
31	7.8				y

(No = N = Excursion) Total N's **0**

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 **00018**

System Name: Scrabell Hill Water

Entry Point: Yih Tank/pump station

Sample Period: \_\_\_\_\_  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	<b>7.2</b>	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Montie TORGESSON

Signature: [Signature]

Date: 11-2-21

Send to DWP within 10 days after end of sampling period