

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.7				Y
3	7.8				Y
4	7.8				Y
5	7.8				Y
6	7.8				Y
7	7.8				Y
8	7.9				Y
9	7.9				Y
10	7.8				Y
11	7.7				Y
12	7.8				Y
13	7.9				Y
14	7.6				Y
15	7.6				Y
16	7.7				Y
17	7.7				Y
18	7.8				Y
19	7.8				Y
20	7.9				Y
21	7.7				Y
22	7.7				Y
23	7.8				Y
24	7.8				Y
25	7.8				Y
26	7.6				Y
27	7.8				Y
28	7.7				Y
29	7.9				Y
30	7.9				Y
31	7.9				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 **00018**

System Name: Scaravel Hill Water
 Entry Point: Yih Tank/pump station
 Sample Period: MAY 22
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Montie TORGESSON
 Signature: [Signature]
 Date: 6-1-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's **0**