

Day	pH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.6				Y
3	7.6				Y
4	7.7				Y
5	7.7				Y
6	7.6				Y
7	7.7				Y
8	7.8				Y
9	7.7				Y
10	7.6				Y
11	7.8				Y
12	7.8				Y
13	7.7				Y
14	7.7				Y
15	7.7				Y
16	7.6				Y
17	7.7				Y
18	7.7				Y
19	7.6				Y
20	7.7				Y
21	7.8				Y
22	7.8				Y
23	8.0				Y
24	8.1				Y
25	8.0				Y
26	8.0				Y
27	8.1				Y
28	8.1				Y
29	8.0				Y
30	8.1				Y
31	8.0				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scravel Hill Water
 Entry Point: Yih Tank/pump station
 Sample Period: Aug 22
 Month/Year


Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Montie TORGESSON
 Signature: 
 Date: 9-1-22

Send to DWP within 10 days after end of sampling period