

Day	pH	Alk	Phos	Other	Y/N
1	8.3				y
2	8.3				y
3	8.3				y
4	8.2				y
5	8.1				y
6	8.2				y
7	8.3				y
8	8.3				y
9	8.1				y
10	8.1				y
11	8.1				y
12	8.2				y
13	8.3				y
14	8.3				y
15	8.4				y
16	8.4				y
17	8.3				y
18	8.3				y
19	8.2				y
20	8.3				y
21	8.3				y
22	8.2				y
23	8.2				y
24	8.3				y
25	8.4				y
26	8.3				y
27	8.3				y
28	8.4				y
29	8.3				y
30	8.4				y
31	8.4				y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scaravel Hill Water
 Entry Point: Yih Tank/pump station
 Sample Period: OCT 22
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Montie TORGESSON
 Signature: *[Signature]*
 Date: 11-7-22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0