

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.3				Y
2	8.2				Y
3	8.2				Y
4	8.1				Y
5	8.2				Y
6	8.2				Y
7	8.0				Y
8	8.1				Y
9	8.1				Y
10	8.3				Y
11	8.3				Y
12	8.1				Y
13	8.1				Y
14	8.2				Y
15	8.1				Y
16	8.1				Y
17	8.2				Y
18	8.2				Y
19	8.3				Y
20	8.3				Y
21	8.3				Y
22	8.1				Y
23	8.0				Y
24	7.9				Y
25	7.9				Y
26	7.9				Y
27	7.9				Y
28	7.8				Y
29	7.8				Y
30	7.9				Y
31	7.8				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scaravel Hill Water
 Entry Point: Yih TANK/pump station
 Sample Period: 12-22
 Month/Year


Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: Montie TORGESON
 Signature: 
 Date: 1-2-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0