

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.8				y
2	7.8				y
3	7.9				y
4	7.8				y
5	8.0				y
6	7.9				y
7	8.0				y
8	8.1				y
9	7.9				y
10	7.9				y
11	7.9				y
12	7.8				y
13	7.8				y
14	7.9				y
15	7.8				y
16	7.8				y
17	7.9				y
18	7.7				y
19	7.7				y
20	7.8				y
21	7.7				y
22	7.7				y
23	7.7				y
24	7.8				y
25	7.7				y
26	7.7				y
27	7.7				y
28	7.6				y
29	7.7				y
30	7.7				y
31	7.6				y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scaravel Hill Water
 Entry Point: Yih TANK/pump station
 Sample Period: 1-23
 Month/Year


Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Montie TORGESSON
 Signature: 
 Date: 2-1-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0