

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.8				Y
3	7.7				Y
4	7.7				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.8				Y
10	7.7				Y
11	7.6				Y
12	7.7				Y
13	7.7				Y
14	7.8				Y
15	7.7				Y
16	7.7				Y
17	7.7				Y
18	7.6				Y
19	7.6				Y
20	7.7				Y
21	7.7				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25	7.7				Y
26	7.7				Y
27	7.6				Y
28	7.5				Y
29	7.5				Y
30	7.6				Y
31	7.7				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scare Hill Water

Entry Point: Yih Tank/pump station

Sample Period: 3-23
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Montie TORGESSON

Signature: *Montie Torgesson*

Date: 4-17-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0