

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.8				Y
3	7.8				Y
4	7.8				Y
5	7.7				Y
6	7.9				Y
7	7.9				Y
8	7.9				Y
9	7.8				Y
10	8.0				Y
11	8.1				Y
12	8.1				Y
13	7.9				Y
14	7.9				Y
15	7.9				Y
16	7.8				Y
17	7.7				Y
18	7.7				Y
19	7.6				Y
20	7.6				Y
21	7.7				Y
22	7.6				Y
23	7.7				Y
24	7.7				Y
25	7.8				Y
26	7.8				Y
27	7.9				Y
28	8.1				Y
29	8.1				Y
30	7.9				Y
31	7.8				Y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scaravel Hill Water

Entry Point: Yih Tank/pump station

Sample Period: 5-2023
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Montie TORGESON

Signature: *Montie Torgeson*

Date: 5-1-2023

Send to DWP within 10 days after end of sampling period