



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.9				Y
3	7.9				Y
4	7.9				Y
5	7.8				Y
6	7.8				Y
7	7.8				Y
8	7.7				Y
9	7.7				Y
10	7.8				Y
11	7.8				Y
12	7.7				Y
13	7.9				Y
14	7.9				Y
15	7.8				Y
16	7.8				Y
17	7.7				Y
18	7.7				Y
19	7.7				Y
20	7.8				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.7				Y
25	7.6				Y
26	7.7				Y
27	7.7				Y
28	7.6				Y
29	7.6				Y
30	7.6				Y
31	7.8				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scrabell Hill Water

Entry Point: Yih Tank/pump station

Sample Period: Aug 2023
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Montie TORRESON

Signature:

Date: 7-1-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0