



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	8.0				Y
4	8.0				Y
5	8.0				Y
6	7.8				Y
7	7.8				Y
8	7.7				Y
9	7.8				Y
10	7.8				Y
11	7.7				Y
12	7.7				Y
13	7.7				Y
14	7.9				Y
15	7.9				Y
16	7.9				Y
17	8.1				Y
18	8.1				Y
19	8.1				Y
20	7.9				Y
21	7.9				Y
22	7.7				Y
23	7.7				Y
24	7.8				Y
25	7.9				Y
26	7.7				Y
27	7.7				Y
28	7.8				Y
29	7.8				Y
30	8.0				Y
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scravel Hill Water

Entry Point: Yih TANK/pump station

Sample Period: Sept 23
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Montie TORGESSON

Signature: *Montie Torgesson*

Date: 10-2-23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0