

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.6				Y
7	7.7				Y
8	7.7				Y
9	7.6				Y
10	7.5				Y
11	7.5				Y
12	7.4				Y
13	7.4				Y
14	7.5				Y
15	7.5				Y
16	7.5				Y
17	7.6				Y
18	7.4				Y
19	7.4				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.5				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.5				Y
29	7.5				Y
30	7.4				Y
31					

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scaravel Hill Water
 Entry Point: Yih Tank/pump station
 Sample Period: June 2024
 Month/Year


Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Montie TORGESSON
 Signature: 
 Date: 6/30-24

Send to DWP within 10 days after end of sampling period