

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				y
2	7.5				y
3	7.5				y
4	7.4				y
5	7.4				y
6	7.4				y
7	7.5				y
8	7.5				y
9	7.5				y
10	7.4				y
11	7.4				y
12	7.4				y
13	7.4				y
14	7.5				y
15	7.4				y
16	7.5				y
17	7.4				y
18	7.4				y
19	7.6				y
20	7.6				y
21	7.6				y
22	7.5				y
23	7.6				y
24	7.6				y
25	7.5				y
26	7.5				y
27	7.7				y
28	7.6				y
29	7.6				y
30	7.6				y
31	7.6				y

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scaravel Hill Water

Entry Point: Yih Tank/pump station

Sample Period: Oct 2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Montie TORGESSON

Signature: *Montie Torgesson*

Date: 11-1-24

Send to DWP within 10 days after end of sampling period