

Day	pH	Alk	Phos	Other	Y/N
1	7.5				y
2	7.5				y
3	7.5				y
4	7.6				y
5	7.7				y
6	7.6				y
7	7.6				y
8	7.7				y
9	7.5				y
10	7.5				y
11	7.5				y
12	7.6				y
13	7.6				y
14	7.4				y
15	7.4				y
16	7.4				y
17	7.5				y
18	7.5				y
19	7.5				y
20	7.5				y
21	7.4				y
22	7.5				y
23	7.5				y
24	7.4				y
25	7.4				y
26	7.4				y
27	7.5				y
28	7.4				y
29	7.4				y
30	7.4				y
31	7.4				y

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scaravel Hill Water

Entry Point: Yih Tank/pump station

Sample Period: 1-25
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Montie TORRESON

Signature: [Signature]

Date: 2-2-2025

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>