

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				y
2	7.4				y
3	7.5				y
4	7.5				y
5	7.5				y
6	7.4				y
7	7.5				y
8	7.6				y
9	7.6				y
10	7.6				y
11	7.5				y
12	7.5				y
13	7.6				y
14	7.5				y
15	7.5				y
16	7.7				y
17	7.7				y
18	7.5				y
19	7.5				y
20	7.4				y
21	7.4				y
22	7.5				y
23	7.4				y
24	7.4				y
25	7.4				y
26	7.5				y
27	7.4				y
28	7.4				y
29	7.4				y
30	7.5				y
31	7.4				y

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scraper Hill Water

Entry Point: Sunset Tank/pump station

Sample Period: MARCH 2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Montie TORRESON

Signature: Montie Torreson

Date: 4-1-25

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>