

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.5				Y
3	7.5				Y
4	7.4				Y
5	7.4				Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.6				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.4				Y
14	7.4				Y
15	7.4				Y
16	7.5				Y
17	7.5				Y
18	7.5				Y
19	7.4				Y
20	7.5				Y
21	7.5				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25	7.6				Y
26	7.4				Y
27	7.4				Y
28	7.5				Y
29	7.5				Y
30	7.4				Y
31					

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scraev Hill Water

Entry Point: Sunset TANK/pump station

Sample Period: 4-25
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Montie TORRESON

Signature: Montie Torreson

Date: 5-1-25

Send to DWP within 10 days after end of
sampling period