

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.6				Y
3	7.6				Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.5				Y
8	7.5				Y
9	7.4				Y
10	7.4				Y
11	7.4				Y
12	7.6				Y
13	7.6				Y
14	7.5				Y
15	7.5				Y
16	7.5				Y
17	7.6				Y
18	7.5				Y
19	7.6				X
20	7.5				X
21	7.5				Y
22	7.4				Y
23	7.4				Y
24	7.4				Y
25	7.6				Y
26	7.5				Y
27	7.4				Y
28	7.4				Y
29	7.4				Y
30	7.5				Y
31	7.4				X

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00018

System Name: Scaravel Hill Water

Entry Point: Sunset Tank/pump station

Sample Period: 5-2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Montie TORGESON

Signature: Montie Torgeson

Date: 6-2-25

Send to DWP within 10 days after end of sampling period