

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.3				Y
3	7.3				Y
4	7.4				Y
5	7.5				Y
6	7.5				Y
7	7.4				Y
8	7.4				Y
9	7.6				Y
10	7.6				Y
11	7.6				Y
12	7.5				Y
13	7.5				Y
14	7.6				Y
15	7.5				Y
16	7.5				Y
17	7.4				Y
18	7.4				Y
19	7.4				Y
20	7.5				Y
21	7.4				Y
22	7.4				Y
23	7.5				Y
24	7.5				Y
25	7.5				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.5				Y
30	7.4				Y
31	7.4				Y

(No = N = Excursion) Total N's

0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

00018

System Name: Scrapel Hill Water

Entry Point: Sunset Tank/pump station

Sample Period: Oct 25

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set by

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Montie Torgeson

Signature: Montie Torgeson

Date: 11-2-25

Send to DWP within 10 days after end of
sampling period