

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.4				Y
4					
5					
6					
7					
8					
9					
10	7.3				Y
11					
12					
13					
14					
15					
16					
17					
18					
19	7.6				Y
20					
21					
22					
23					
24					
25					
26					
27					
28					
29	7.2				Y
30					
31					

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 00029

System Name: Periwinkle Mobile Estate

Entry Point: Well

Sample Period: July 2022  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

### Minimum Water Quality Parameters as set by

RECEIVED  
AUG 08 2022

Data Mgmt & Compliance  
Drinking Water Program

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		( )

Print Name: Gregory Attwell

Signature: [Signature]

Date: 8.3.2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's: 0