

RECEIVED

FEB 07 2024

Certification Drinking Water Service

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6	7.4				
7					
8					
9					
10					
11					
12					
13	7.9				
14					
15					
16	7.6				
17					
18	7.4				
19					
20					
21					
22	7.5				
23					
24					
25	7.3				
26					
27					
28	7.4				
29	7.3				
30					
31	7.2				

BC →

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Periwinkle Mobile Estate

Entry Point: Well

Sample Period: 12 2023
Month Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other

Print Name: Greg Atwell

Signature: [Signature]

Date: 02-01-2024

Send to DWP within 10 days after end of sampling period

*No = N = Excursion) Total N's