

Lead & Copper Rule Corrosion Control

February

Day	pH	Alk	Phos	Other	Y/N
1	7.2				
2					
3	7.2				
4	7.3				
5					
6	7.4				
7	7.4				
8	7.4				
9					
10	7.3				
11					
12	7.3				
13					
14	7.2				
15					
16	7.4				
17	7.4				
18	7.4				
19					
20	7.2				
21					
22	7.3				
23	7.3				
24					
25	7.3				
26	7.4				
27					
28	7.2				
29					
30	7.2				
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

☐ ☐ ☐ ☐ ☐ ☐

System Name: Periwinkle Mobile Estate

Entry Point: Well

Sample Period: January 2025
Month/Year

Number of excursions* during this month: 7

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 2

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Greg Attrell

Signature: [Signature]

Date: 02-03-2026

Send to DWP within 10 days after end of sampling period

*No = N = Excursion) Total N's

7