

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				
2					
3	7.2				
4	7.3				
5	7.3				
6					
7					
8					
9	7.4				
10	7.4				
11					
12					
13	7.3				
14	7.2				
15					
16					
17					
18	7.3				
19	7.3				
20					
21					
22					
23	7.4				
24	7.3				
25					
26					
27					
28	7.3				
29	7.3				
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

☐ ☐ ☐ ☐ ☐

System Name: Periwinkle Mobile Estate

Entry Point: Well

Sample Period: March 2024

Month Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk (Alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Greg Attrell

Signature: Greg Attrell

Date: 04-01-2024

Send to DWP within 10 days after end of sampling period

*No = N = Excursion) Total N's

☐