

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.6				
4					
5					
6					
7					
8					
9					
10					
11	7.4				
12					
13					
14					
15					
16	7.6				
17					
18					
19					
20					
21					
22					
23	7.2				
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Periwinkle Mobile Estate

Entry Point: Well

Sample Period: August 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

RECEIVED
SEP 14 2021
Data Mgmt & Compliance
Drinking Water Program

Print Name: Shawn Atwell

Signature: [Signature]

Date: _____

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's