

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4					
5					
6					
7	7.2				
8					
9					
10					
11					
12					
13					
14					
15					
16	7.2				
17					
18					
19					
20					
21					
22	7.2				
23					
24	7.4				
25					
26					
27					
28	7.2				
29					
30					
31	7.2				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Periwinkle Mobile Estate

Entry Point: Well

Sample Period: December 2022
Month/Year

Number of excursions* during this month:
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Greg Attrell

Signature: [Signature]

Date: 01-02-2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0