



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.9	47			Y
2	7.5	48			Y
3	7.5	50			Y
4	OFF	OFF			
5	OFF	OFF			
6	7.8	50			Y
7	8.9	52			Y
8	7.5	48			Y
9	OFF	OFF			
10	OFF	OFF			
11	7.6	48			Y
12	7.7	50			Y
13	OFF	OFF			
14	7.5	50			Y
15	7.9	49			Y
16	7.5	50			Y
17	7.6	48			Y
18	OFF	OFF			
19	OFF	OFF			
20	7.5	40			Y
21	7.5	45			Y
22	OFF	OFF			
23	OFF	OFF			
24	7.7	30			Y
25	7.7	35			Y
26	7.8	40			Y
27	7.6	36			Y
28	OFF	OFF			
29	OFF	OFF			
30	7.5	44			Y
31	7.6	48			Y

<< Have minimums been met for this day?

<b>ENTRY POINT</b>							
PWS ID:	4	1	0	0	0	4	1
System Name:	City of Amity						
Entry Point:	EP-D						
Sample Period:	Jan-21						
	Month / Year						

**Number of excursions\* during this month:**   
 (Count the number of days when any WQP was less then the minimum required)

**Total excursions during the previous 5 months:**   
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

<b>Minimum Water Quality Parameters as set by State:</b>	
pH	<input type="text" value="7.5"/>
Alk	<input type="text" value="30"/> (Alkalinity)
PO4	<input type="text"/> (Orthophosphate)
Sili	<input type="text"/> (Silicate)

**Print Name:** Richard A. Howard Sr.

**Signature:** *Richard A. Howard Sr.*

**Date:** Monday, February 1, 2021

(NO=N=Excursions) **Total N's**