



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	OFF	OFF			
2	OFF	OFF			
3	7.5	48			Y
4	7.5	45			Y
5	8.0	42			Y
6	7.6	52			Y
7	OFF	OFF			
8	8.2	54			Y
9	7.5	48			Y
10	7.7	56			Y
11	7.5	52			Y
12	OFF	OFF			
13	OFF	OFF			
14	OFF	OFF			
15	OFF	OFF			
16	7.8	42			Y
17	7.5	44			Y
18	8.6	48			Y
19	8.7	66			Y
20	8.3	52			Y
21	OFF	OFF			
22	OFF	OFF			
23	7.5	41			Y
24	OFF	OFF			
25	OFF	OFF			
26	8.8	56			Y
27	OFF	OFF			
28	7.8	56			Y
29					
30					
31					

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Feb-21
 Month / Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH

7.5

 Alk

30

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Sili

--

 (Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Sunday, March 7, 2021

(NO=N=Excursions) Total N's

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381