



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	50			Y
2	OFF	OFF			
3	8.1	52			Y
4	OFF	OFF			
5	7.7	58			Y
6	7.5	52			Y
7	OFF	OFF			
8	OFF	OFF			
9	7.9	44			Y
10	8.6	60			Y
11	OFF	OFF			
12	OFF	OFF			
13	OFF	OFF			
14	8.1	58			Y
15	7.8	56			Y
16	7.8	56			Y
17	8.3	46			Y
18	OFF	OFF			
19	OFF	OFF			
20	8.8	42			Y
21	8.9	42			Y
22	OFF	OFF			
23	OFF	OFF			
24	8.4	38			Y
25	8.4	44			Y
26	OFF	OFF			
27	OFF	OFF			
28	8.3	30			Y
29	8.6	34			Y
30	OFF	OFF			
31	OFF	OFF			

<< Have minimums been met for this day?

ENTRY POINT

PWS ID:

4	1	0	0	0	4	1
---	---	---	---	---	---	---

System Name: City of Amity
 Entry Point: EP-D
 Sample Period: Mar-21
 Month / Year

Number of excursions* during this month:

0

(Count the number of days when any WQP was less then the minimum required)

Total excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.5	
Alk	30	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Richard A. Howard Sr.

Signature: *Richard A. Howard Sr.*

Date: Sunday, April 4, 2021

(NO=N=Excursions) Total N's

0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, Or 97293-0350 Phone (503) 731-4381